

CERTIFICATE OF CONFORMITY

Electrical Cabinets

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

MODEL:

FC - Air-Conditioned Field Cabinets, Steel, T33 Smoke Blue

PRODUCTS:

IP-1079062-ACKIT	IP-1379062-ACKIT	IP-1679080-ACKIT	IP-1979080-ACKIT	IP-2279080-ACKIT
IP-10716562-ACKIT	IP-13716562-ACKIT	IP-16716580-ACKIT	IP-19716580-ACKIT	

STANDARDS & CONFORMITIES:

IEC/EN 60529, IEC/EN 62208, EIA-310-D, RoHS, AS/NZS 60335.2.40:2019, AS/NZS 60335.1:2020, SAA203165, CE, UKCA

PROTECTION RATING:

IP55, IK10

CERTIFICATES:

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 2009.33.02/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

CE Certificate of Compliance: Certificate SZT-24 MA 33485-1

UKCA Certificate of Compliance: Certificate SZT-25 MA 38734-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

IP ENCLOSURES PTY LTD

Revision: May 1, 2026