

**CERTIFICATE OF CONFORMITY – Electrical Cabinets**

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

**MODEL:**

FC – Field Cabinets, Steel

**PRODUCTS:**

IP-453522-0	IP-654532-0	IP-706032-0	IP-453522	IP-654532	IP-706032
IP-1077562-0	IP-1077580-0	IP-1377562-0	IP-1377580-0	IP-13775100-0	IP-1677562-0
IP-1677580-0	IP-16775100-0	IP-1977562-0	IP-1977580-0	IP-19775100-0	IP-2277562-0
IP-2277580-0	IP-1077562	IP-1077580	IP-1377562	IP-1377580	IP-13775100
IP-1677562	IP-1677580	IP-16775100	IP-1977562	IP-1977580	IP-19775100
IP-2277562	IP-2277580	IP-10715062-0	IP-10715080-0	IP-13715062-0	IP-13715080-0
IP-16715062-0	IP-16715080-0	IP-22716580	IP-10715062	IP-10715080	IP-13715062
IP-13715080	IP-16715062	IP-16715080			

(Non-ventilated products with suffix “-0” are IP66 otherwise IP55 with IP-V2000/2200 vents/fans fitted)

**STANDARDS (& CONFORMITIES):**

IEC/EN 60529, IEC/EN 62208, CE, UKCA

**PROTECTION RATING:**

IP66, IK10

**CERTIFICATES:**

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 2009.33.02/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1

UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.



Leigh Radloff  
Product Manager  
January 18, 2024