

CERTIFICATE OF CONFORMITY – Electrical Cabinets

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

MODEL:

FCA – Field Cabinets, Aluminium

PRODUCTS:

| | | | |
|----------------|----------------|----------------|----------------|
| IP-A453522-0 | IP-A654532-0 | IP-A706032-0 | IP-A453522 |
| IP-A654532 | IP-A706032 | IP-A1077562-0 | IP-A1077580-0 |
| IP-A1377562-0 | IP-A1377580-0 | IP-A1677562-0 | IP-A1677580-0 |
| IP-A1977562-0 | IP-A1977580-0 | IP-A2277562-0 | IP-A2277580-0 |
| IP-A1077562 | IP-A1077580 | IP-A1377562 | IP-A1377580 |
| IP-A1677562 | IP-A1677580 | IP-A1977562 | IP-A1977580 |
| IP-A2277562 | IP-A2277580 | IP-A10715062-0 | IP-A10715080-0 |
| IP-A13715062-0 | IP-A13715080-0 | IP-A16715062-0 | IP-A16715080-0 |
| IP-A22716580 | IP-A10715062 | IP-A10715080 | IP-A13715062 |
| IP-A13715080 | IP-A16715062 | IP-A16715080 | |

(Non-ventilated products with suffix "-0" are IP66 otherwise IP55 with IP-V2000/2200 vents/fans fitted)

STANDARDS (& CONFORMITIES):

IEC/EN 60529, IEC/EN 62208, CE, UKCA

PROTECTION RATING:

IP66, IK10

CERTIFICATES:

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 2009.33.02/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1

UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

IP ENCLOSURES PTY LTD

Revision: August 20, 2024