

CERTIFICATE OF CONFORMITY – Electrical Cabinets

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

MODEL:

FCA – Field Cabinets, Aluminium

PRODUCTS:

IP-A453522-0	IP-A654532-0	IP-A706032-0	IP-A453522
IP-A654532	IP-A706032	IP-A1077562-0	IP-A1077580-0
IP-A1377562-0	IP-A1377580-0	IP-A1677562-0	IP-A1677580-0
IP-A1977562-0	IP-A1977580-0	IP-A2277562-0	IP-A2277580-0
IP-A1077562	IP-A1077580	IP-A1377562	IP-A1377580
IP-A1677562	IP-A1677580	IP-A1977562	IP-A1977580
IP-A2277562	IP-A2277580	IP-A10715062-0	IP-A10715080-0
IP-A13715062-0	IP-A13715080-0	IP-A16715062-0	IP-A16715080-0
IP-A22716580	IP-A10715062	IP-A10715080	IP-A13715062
IP-A13715080	IP-A16715062	IP-A16715080	

(Non-ventilated products with suffix “-0” are IP66 otherwise IP55 with IP-V2000/2200 vents/fans fitted)

STANDARDS (& CONFORMITIES):

IEC/EN 60529, IEC/EN 62208, CE, UKCA

PROTECTION RATING:

IP66, IK10

CERTIFICATES:

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 2009.33.02/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1

UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.



Leigh Radloff
Product Manager
January 18, 2024