

#### IP ENCLOSURES PTY LTD

ABN 17 168 921 319

19-27 Fred Chaplin Circuit, Bells Creek QLD 4551

T: 1300 576 094

www.ipenclosures.com.au | sales@ipenclosures.com.au

# **CERTIFICATE OF CONFORMITY – Electrical Enclosures**

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

#### MODEL:

SS2 - Wall Mounted Electrical Enclosures, Stainless Steel

### PRODUCTS:

IP-SS10010030	IP-SS10010040	IP-SS12010030	IP-SS12010040
IP-SS12012030	IP-SS12012040	IP-SSL4010030	IP-SSL4010040
IP-SSL6010030	IP-SSL6010040	IP-SSL4012030	IP-SSL4012040
IP-SSL6012030	IP-SSL6012040	IP-304-10010030	IP-304-10010040
IP-304-12010030	IP-304-12010040	IP-304-12012030	IP-304-12012040
IP-304-L4010030	IP-304-L4010040	IP-304-L6010030	IP-304-L6010040
IP-304-L4012030	IP-SSL4012040	IP-304-L6012030	IP-304-L6012040

## STANDARDS (& CONFORMITIES):

IEC/EN 60529, IEC/EN 62208, IEC/EN 61439, CE, UKCA

## **PROTECTION RATING:**

IP55, IK10

# **Enclosures**

# **CERTIFICATES:**

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 1610.05.01/00 IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

IEC/EN61439-1, 61439-2 Low voltage switchgear and controlgear assemblies: Certificate AB-0341-T, 23-314-R1-N1-1

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1 UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

IP ENCLOSURES PTY LTD Revision: August 20, 2024