

IP ENCLOSURES PTY LTD

ABN 17 168 921 319

19-27 Fred Chaplin Circuit, Bells Creek QLD 4551

T: 1300 576 094

www.ipenclosures.com.au | sales@ipenclosures.com.au

CERTIFICATE OF CONFORMITY – Electrical Enclosures

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

MODEL:

SSHMI - HMI Electrical Enclosures, Stainless Steel

PRODUCTS:

IP-SSHMI303015 IP-SSHMI304015 IP-SSHMI304025 IP-SSHMI354515

IP-SSHMI354525 IP-SSHMI406015 IP-SSHMI406025

STANDARDS (& CONFORMITIES):

IEC/EN 62208, CE, UKCA

PROTECTION RATING:

IP66, IK10

CERTIFICATES:

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1 UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

Leigh Radloff Product Manager January 18, 2024